



Date 13/04/2023 Gas Safe Register No

937181

Gas Safe Register Licence Number

5451573

Serial No

53789016

Smart Certs

LANDLORD/HOMEOWNER GAS SAFETY RECORD

DETAILS OF LANDLORD/HOMEOWNER (or agent where appropriate)	ION		DETAILS OF REGISTERED BUSINESS								
Heritage Care UK 24 Lloyds Way Beckenham	24 Lloyds Way Beckenham		DD2 201	Smart Certs 19 High Street Wanstead London		Γ11 Ω Λ Λ					
BR3 3QL			BR3 3QL	N/A		E11 2AA					
Gas safety inspection											
DEFECTS IDENTIFIED	Warring Nation Inquests	GAS INSTALLATION P	PIPEWORK								
1	Warning Notice Issued?	Pipework visual inspection	Outcome of gas supply pipework visual inspection	Is the Emergency Control Valve access satisfactory?	Outcome of gas tightness test?	Is protective equipotential bonding satisfactory?					
3 4 5				✓	✓	✓					
ANY REMEDIAL ACTION TAKEN OR NOTES Numbers should correspond	ond to defects above										
	Record issued by:										
		Signature		Name (Capitals)							
		1 / m		W Koreshi		ATTENTION Next safety check					
BS50291 compliant CO alarm should be installed		Record received k	by: (tennant/landlord/h	omeowner/agent)	alua las o						
		Signature		Name (Capitals)	13	3/04/2024					
				N/A							

This record can be used to document the outcomes of the checks and tests required by The Gas Safety (Installation and Use) Regulations. Some of the outcomes are as a result of visual inspection only and are recorded as appropriate. Unless specifically recorded no detailed inspection of the flue lining, construction or integrity has been performed

Produced using iCertifi Gas Edition © Report pages 1 of 2

Certificate Reference: 53789016

APPLIANCE DETAILS				APPLIANCE RESULTS											
Appliance Number	Location	Туре	Manufacturer	Model	Owned by Landlord/ homeowner?	Inspected Yes/No?	Type of Flue	Operating pressure in mbar &/or heat input kW/ h or Btu/h	Operation of safety device(s) Pass/Fail or N/A	Ventilation Satisfactory Yes/No	Visual condition of flue & termination Pass/Fail N/A	Flue operation checks Pass/ Fail/N/A	Combustion analyser reading (if applicable)	Serviced Yes/No?	Safe to use Yes/No?
		Deiler	Vallant	Factor Phys 000		V					Dana		0.0000	Nie	
Avalible	Cupboard	Boiler	Vaillant	Ecotec Plus 838	Yes	Yes	RS	20mb	Pass	Yes	Pass	N/A	0.0009	No	
Approved CO alarm fitted?															
Audible C	O Alarm						1								
Approved CO alarm fitted?	Is CO alarm In Date? CO alarm test satisfactory?														
				T T	I		ı	Γ	Ī			Γ			
Approved CO alarm fitted?															
Audible C Approved CO alarm fitted?															
Audible C Approved CO alarm fitted?															